



2012003084M

检测报告

告

16

限公司

研究中心
Materials Industry





2012003084M

检 验 报 告

TEST REPORT

中心编号(No.): 201402CW116

第 1 页 共 2 页

样品名称	PVC 编织地毯	检验类别	委托检验
委托单位	安吉艺科装饰材料科技有限公司	商 标	ECO BEAUTY 艺科美
生产单位	安吉艺科装饰材料科技有限公司	等 级	—
生产日期	2013 年 12 月 18 日	样品编号	—
来样日期	2014 年 02 月 17 日	规格型号	50 cm × 50cm
样品数量	4 块	样品状态	块状
检验依据	GB18586-2001《室内装饰装修材料 聚氯乙烯卷材地板中有害物质限量》		
检验项目	1. 挥发物		
检验结论	*经检验, 送检样品的挥发物的检验结果符合标准 GB18586-2001 的技术指标要求。*		
备注: 生产批号: 20131218。			



批 准:

审核: 萧 斌

编 制:

2014年03月20日

检验单位地址: 北京市朝阳区管庄中国建材院内北楼

电话: 010-51164723

邮编: 100024



告 报 金 检

TEST REPORT

中心编号(No.): 201402CW116

第 2 页 共 2 页

样品类型		非发泡类其他基材		
序号	检验项目	标准要求	检验结果	单项结论
1	挥发物/g/m ²	≤10	7.4	合格
(以下空白)				
备注: (此处空白)				

檢驗單位地址：北京市朝陽區管庄由園建林院內北樓
電話：010-51164723

邮编: 100024

说 明 Notice

- 1、本报告无中心“检验检测印章”和骑缝章无效。
This test report is invalid without the seal.
- 2、本报告无“编制、审核、批准”签字无效。
This test report is invalid without the signatures of the related persons.
- 3、本报告涂改、部分复印无效。
This test report is invalid if erased, altered or copied partially.
- 4、对本报告若有异议，应于收到报告之日起十五个工作日内向本中心提出，逾期恕不受理。

Any doubt should inform us within 15 workdays after receiving the test report.
委托检验样品和委托信息由委托人提供，中心不对真实性负责，委托检验结果仅对来样负责。

The commissioned testing samples and commission information are provided by the applicant. The results shown in the test report refer only to the sample(s) tested unless otherwise stated. Identifying authenticity of the supplied samples and information is out of our responsibility.

- 6、本报告的法律责任由建筑材料工业技术监督研究中心承担。

The legal responsibility of this test report is charged with Technical Supervision and Research Center of the Building Materials Industry.

- 7、本报告采用防伪纸张，复印后应带有网络底纹。

This test report is printed on anti-counterfeiting paper. Its copy should have grid shading.

本中心联系方式:

地址 (Address): 北京市朝阳区管庄东里一号北楼

No.1 Guanzhuang Dongli, Chaoyang District, Beijing 100024, P.R. China

邮编 (Post Code): 100024

电话 (Tel): (010) 51164723 51164718

传真 (Fax): (010) 51164724

网址 (Web): <http://www.dmtc.org.cn/>

电子邮箱 (E-mail): dmtc2007@163.com



(国家)建筑材料工业技术监督研究中心

Technical Supervision and Research Center of the Building Materials Industry

DMTC